



NOTES:

- ALL PIPE SHALL BE INSTALLED IN ACCORDANCE WITH ASTM D2321 - STANDARD PRACTICE FOR UNDERGROUND INSTALLATION OF FLEXIBLE THERMOPLASTIC SEWER PIPE, LATEST EDITION.
- DUE TO SLIGHT DIFFERENCES IN PRINSCO'S MANUFACTURING EQUIPMENT, 18"-48" (450-1200 MM) DIAMETER PIPE HAS MINOR DIAMETRICAL DIFFERENCES BETWEEN THE WESTCOAST AND THE MIDWEST. DUE TO THESE DIFFERENCES PLEASE VERIFY DIMENSIONS BEFORE ORDERING ANY KOR-N-SEAL PRODUCT.
- SEE KOR-N-SEAL FOR SPECIFIC PRODUCT INFORMATION AND SELECTION.
- KOR-N-SEAL IS A REGISTERED TRADEMARK OF TRELLEBORG, INC. (WWW.TRELLEBORG.COM).
- SEE STRUCTURE CONNECTION INSTALLATION DETAIL (D-1-109) FOR PROPER BACKFILLING TECHNIQUES NEAR STRUCTURES.

PIPE SIZE in (mm)	PVC ADAPTER OD in (mm)	KOR-N-SEAL (PN#)	
		SERIES 106 OR 206	SERIES 306
12 (300)	12.5 (318)	S106-16AWS	NA
15 (375)	15.3 (389)	S206-18L	NA
18 (450)	18.7 (475)	S206-24A	S306-22
24 (600)	24.1 (612)	S206-28	S306-28
30 (750)	32 (813)	S206-36	S306-36

THIS DETAIL DEPICTS RECOMMENDED INSTALLATION PRACTICES AND IS NOT INTENDED TO SUPERSEDE ANY NATIONAL, STATE OR LOCAL SPECIFICATIONS. PRINSCO BEARS NO RESPONSIBILITY FOR ANY ALTERATIONS, REVISION AND/OR DEVIATION FROM THIS STANDARD DETAIL. PRINSCO HAS NOT PERFORMED ANY ENGINEERING OR DESIGN SERVICE FOR THIS PROJECT. THE DESIGN ENGINEER SHALL REVIEW THESE DETAILS PRIOR TO CONSTRUCTION TO VERIFY SUITABILITY. © PRINSCO, INC.



1717 16TH ST. NE
WILLMAR, MN 56201
www.prinsco.com

TITLE: HDPE PIPE - STRUCTURE CONNECTION - KOR-N-SEAL WITH PVC ADAPTER		REV: B
DRAWN BY: TRA	DATE: 30-Jun-17	DRAWING NUMBER: D-1-117
SCALE: NTS	SHEET: 1 OF 1	