



TRAFFIC RATED VALVE BOX DETAIL

**NOTES:**

1. A 4" (100 mm) INSPECTION PORT MAY BE CONNECTED THROUGH ANY CHAMBER CORRUGATION VALLEY.
2. TAP TEE CONNECTION MAY CONSIST OF QWICKSEAL, INSERTA TEE OR APPROVED EQUAL.
3. ALL PVC FITTINGS TO BE SOLVENT CEMENTED.
4. PVC MAY BE EITHER SDR 35 or SCH 40

THIS DETAIL DEPICTS RECOMMENDED INSTALLATION PRACTICES AND IS NOT INTENDED TO SUPERSEDE ANY NATIONAL, STATE OR LOCAL SPECIFICATIONS. PRINSCO BEARS NO RESPONSIBILITY FOR ANY ALTERATIONS, REVISION AND/OR DEVIATION FROM THIS STANDARD DETAIL. PRINSCO HAS NOT PERFORMED ANY ENGINEERING OR DESIGN SERVICE FOR THIS PROJECT. THE DESIGN ENGINEER SHALL REVIEW THESE DETAILS PRIOR TO CONSTRUCTION TO VERIFY SUITABILITY. © PRINSCO, INC.



**INSPECTION PORT DETAIL  
HYDROSTOR HS180 CHAMBER**

DRAWN BY: BMH  
DATE: 01/20/2016  
SCALE: NTS  
SHEET: 1 OF 1

DRAWING NUMBER:

**D-7-203**