



**NOTES:**

- ALL PIPE SHALL BE INSTALLED IN ACCORDANCE WITH ASTM D2321 - STANDARD PRACTICE FOR UNDERGROUND INSTALLATION OF FLEXIBLE THERMOPLASTIC SEWER PIPE, LATEST EDITION.
- SEE A-LOK FOR SPECIFIC PRODUCT INFORMATION AND SELECTION.
- A-LOK IS A REGISTERED TRADEMARK OF A-LOK PRODUCTS, INC. (WWW.A-LOK.COM)
- SEE STRUCTURE CONNECTION INSTALLATION DETAIL (D-2-109) FOR PROPER BACKFILLING TECHNIQUES NEAR STRUCTURES.

PIPE SIZE in (mm)	MANHOLE ADAPTER OD in (mm)	A-LOK (P/N)
12 (300)	14.74 (374)	480
15 (375)	18.01 (457)	580
18 (450)	21.70 (551)	710
24 (600)	28.39 (721)	915
30 (750)	34.90 (886)	1130
36 (900)	40.84 (1,037)	1320

THIS DETAIL DEPICTS RECOMMENDED INSTALLATION PRACTICES AND IS NOT INTENDED TO SUPERSEDE ANY NATIONAL, STATE OR LOCAL SPECIFICATIONS. PRINSCO BEARS NO RESPONSIBILITY FOR ANY ALTERATIONS, REVISION AND/OR DEVIATION FROM THIS STANDARD DETAIL. PRINSCO HAS NOT PERFORMED ANY ENGINEERING OR DESIGN SERVICE FOR THIS PROJECT. THE DESIGN ENGINEER SHALL REVIEW THESE DETAILS PRIOR TO CONSTRUCTION TO VERIFY SUITABILITY. © PRINSCO, INC.



1717 16TH ST. NE  
WILLMAR, MN 56201  
www.prinsco.com

TITLE: HP PIPE - STRUCTURE CONNECTION - A-LOK WITH PIPE SLEEVE		REV: C
DRAWN BY: TSS	DATE: 17-Aug-17	DRAWING NUMBER: D-2-116
SCALE: NTS	SHEET: 1 OF 1	