



**A**  
135  
CONCRETE ENCASEMENT SECTION DETAIL  
SCALE: NTS

**NOTES:**

- ALL PIPE SHALL BE INSTALLED IN ACCORDANCE WITH ASTM D2321 - STANDARD PRACTICE FOR UNDERGROUND INSTALLATION OF FLEXIBLE THERMOPLASTIC SEWER PIPE, LATEST EDITION.

**APPLICATION NOTES:**

- CONCRETE ENCASEMENT IS ONLY RECOMMENDED FOR USE ON MINIMALLY DAMAGED PIPE FOR A SOIL-TIGHT REPAIR.
- BEFORE POURING CONCRETE, A NON-WOVEN GEOTEXTILE FABRIC SHOULD BE PLACED OVER THE DAMAGED AREA TO PREVENT CONCRETE FROM SEEPING IN.
- CONCRETE SHOULD EXTEND A MINIMUM OF 6" AROUND THE PIPE.

THIS DETAIL DEPICTS RECOMMENDED INSTALLATION PRACTICES AND IS NOT INTENDED TO SUPERSEDE ANY NATIONAL, STATE OR LOCAL SPECIFICATIONS. PRINSCO BEARS NO RESPONSIBILITY FOR ANY ALTERATIONS, REVISION AND/OR DEVIATION FROM THIS STANDARD DETAIL. PRINSCO HAS NOT PERFORMED ANY ENGINEERING OR DESIGN SERVICE FOR THIS PROJECT. THE DESIGN ENGINEER SHALL REVIEW THESE DETAILS PRIOR TO CONSTRUCTION TO VERIFY SUITABILITY. © PRINSCO, INC.



1717 16TH ST. NE  
WILLMAR, MN 56201  
www.prinsco.com

TITLE: HDPE PIPE - PIPE REPAIR - CONCRETE ENCASEMENT		REV: C
DRAWN BY: TRA	DATE: 15-Jun-17	DRAWING NUMBER: D-1-135
SCALE: NTS	SHEET: 1 OF 1	