



GENERAL NOTES:

- GRAVITY FLOW CAPACITY OF 5.25 CFS
- RIPRAP STILLING BASIN RECOMMENDED AT STRUCTURE OUTLET

NOTE 2: 4' MIN. STRUCTURE DIAMETER. 5' MIN. STRUCTURE DIAMETER WHEN USING DISSIPATOR & SKIMMER IN TANDEM

Not to Scale





THE PRESERVERTM CURB CUT DETAIL

ENERGY DISSIPATOR AND/OR SKIMMER

PROUDLY NATERIALS:

-100% recycled HDPE
-5tainless steel brackets
-5tainless steel bardware

CONCEPTUAL PLAN DISCLAIMER:
THIS GENERIC DETAIL DOES NOT ENCOMPASS THE SIZING, FIT, AND
APPLICABILITY OF THE PRESERVER FOR THIS SPECIFIC PROJECT. IT
IS THE ULTIMATE RESPONSIBILITY OF THE DESIGN ENGINEER TO
ASSURE THAT THE STORMWATER SYSTEM DESIGN IS IN FULL
COMPLIANCE WITH ALL APPLICABLE LAWS AND REGULATIONS,
MOMENTUM ENVIRONMENTAL LLC DOES NOT APPROVE PLANS,
SIZING, OR SYSTEM DESIGNS. THE DESIGN ENGINEER IS
RESPONSIBLE FOR ALL DESIGN DECISIONS.