



CONFIGURATION	LATERAL DIAMETER	CORED HOLE DIAMETER	MAINLINE DIAMETERS
4" INTO 24"	4"	4.5"	10" - 24"
4" INTO 60"			30" - 60"
6" INTO 24"	6"	6.5"	12" - 24"
6" INTO 60"			30" - 60"
8" INTO 24"	8"	8.5"	15" - 24"
8" INTO 60"			30" - 60"
10" INTO 24"	10"	10.7"	18" - 24"
10" INTO 60"			30" - 60"
12" INTO 60"	12"	12.0"	24" - 60"

**NOTES:**

1. WHEN PROPERLY INSTALLED, GOLDFLO TAP TEES CREATE A SOIL-TIGHT CONNECTION.
2. GOLDFLO TAP TEES SHOULD NOT BE INSTALLED VERTICALLY ON MAINLINE PIPE.
3. THE CONNECTION SHOULD BE WRAPPED IN A NON-WOVEN GEOTEXTILE AND SURROUNDED WITH CLASS I CRUSHED ROCK BACKFILL TO PROVIDE PROPER SUPPORT TO THE PIPE AND CONNECTION.
4. QUICK DRYING CONSTRUCTION ADHESIVE CAN BE USED ALONG THE MAINLINE-TAP TEE INTERFACE TO CREATE A SOLID CONNECTION AND REDUCE THE POTENTIAL FOR SOIL INFILTRATION.

THIS DETAIL DEPICTS RECOMMENDED INSTALLATION PRACTICES AND IS NOT INTENDED TO SUPERSEDE ANY NATIONAL, STATE OR LOCAL SPECIFICATIONS. PRINSCO BEARS NO RESPONSIBILITY FOR ANY ALTERATIONS, REVISION AND/OR DEVIATION FROM THIS STANDARD DETAIL. PRINSCO HAS NOT PERFORMED ANY ENGINEERING OR DESIGN SERVICE FOR THIS PROJECT. THE DESIGN ENGINEER SHALL REVIEW THESE DETAILS PRIOR TO CONSTRUCTION TO VERIFY SUITABILITY. © PRINSCO, INC.



1717 16TH ST. NE  
WILLMAR, MN 56201  
www.prinsco.com

TITLE: HDPE PIPE - TAPPED CONNECTION - GOLDFLO TAP TEE			
DRAWN BY: TRA	DATE: 23-Jan-23	DRAWING NUMBER:	
SCALE: NTS	SHEET: 1 OF 1	D-1-152	