



A
135
CONCRETE ENCASEMENT SECTION DETAIL
SCALE: NTS

NOTES:

- ALL PIPE SHALL BE INSTALLED IN ACCORDANCE WITH ASTM D2321 - STANDARD PRACTICE FOR UNDERGROUND INSTALLATION OF FLEXIBLE THERMOPLASTIC SEWER PIPE, LATEST EDITION.

APPLICATION NOTES:

- CONCRETE ENCASEMENT IS ONLY RECOMMENDED FOR USE ON MINIMALLY DAMAGED PIPE FOR A SOIL-TIGHT REPAIR.
- BEFORE POURING CONCRETE, A NON-WOVEN GEOTEXTILE FABRIC SHOULD BE PLACED OVER THE DAMAGED AREA TO PREVENT CONCRETE FROM SEEPING IN.
- CONCRETE SHOULD EXTEND A MINIMUM OF 6" AROUND THE PIPE.