



NOTES:

1. SCOUR PROTECTION SHOULD USE A CLASS 1 WOVEN GEOTEXTILE. GEOTEXTILE SHOULD MEET AASHTO M288 CLASS 1 SPECIFICATION.
2. SCOUR PROTECTION IS ONLY NEEDED WITH CHAMBER ROWS CONNECTED TO THE INLET MANIFOLD.

THIS DETAIL DEPICTS RECOMMENDED INSTALLATION PRACTICES AND IS NOT INTENDED TO SUPERSEDE ANY NATIONAL, STATE OR LOCAL SPECIFICATIONS. PRINSCO BEARS NO RESPONSIBILITY FOR ANY ALTERATIONS, REVISION AND/OR DEVIATION FROM THIS STANDARD DETAIL. PRINSCO HAS NOT PERFORMED ANY ENGINEERING OR DESIGN SERVICE FOR THIS PROJECT. THE DESIGN ENGINEER SHALL REVIEW THESE DETAILS PRIOR TO CONSTRUCTION TO VERIFY SUITABILITY. © PRINSCO, INC.

PRINSCO
WATER MANAGEMENT SOLUTIONS

1717 16TH ST. NE
WILLMAR, MN 56201
www.prinSCO.com

| | | | |
|--|-----------------|-------------------------|--|
| TITLE: HYDROSTOR HS31 - SCOUR PROTECTION | | | |
| DRAWN BY: AED | DATE: 08-Aug-24 | DRAWING NUMBER: D-7-407 | |
| SCALE: NTS | SHEET: 1 OF 1 | | |