



NOTES:

- ALL PIPE SHALL BE INSTALLED IN ACCORDANCE WITH ASTM D2321 STANDARD PRACTICE FOR UNDERGROUND INSTALLATION OF FLEXIBLE THERMOPLASTIC SEWER PIPE, LATEST EDITION.
- SEE A-LOK FOR SPECIFIC PRODUCT INFORMATION AND SELECTION.
- A-LOK IS A REGISTERED TRADEMARK OF A-LOK PRODUCTS, INC. (WWW.A-LOK.COM)
- SEE STRUCTURE CONNECTION INSTALLATION DETAIL (D-1-109) FOR PROPER BACKFILLING TECHNIQUES NEAR STRUCTURES.

| PIPE SIZE in (mm) | MANHOLE ADAPTER OD in (mm) | A-LOK (P/N) | |
|----------------------|----------------------------------|-------------|--|
| 12 (300) | 15.0 (380) | 490 | |
| 15 (375) | 18.1 (460) | 580 | |
| 18 (450) | 21.7 (550) | 710 | |
| 24 (600) | 28.6 (725) | 915 | |
| 30 (750) | 35.1 (890) | 1130 | |

THIS DETAIL DEPICTS RECOMMENDED INSTALLATION PRACTICES AND IS NOT INTENDED TO SUPERSEDE ANY NATIONAL, STATE OR LOCAL SPECIFICATIONS. PRINSCO BEARS NO RESPONSIBILITY FOR ANY ALTERATIONS, REVISION AND/OR DEVIATION FROM THIS STANDARD DETAIL. PRINSCO HAS NOT PERFORMED ANY ENGINEERING OR DESIGN SERVICE FOR THIS PROJECT. THE DESIGN ENGINEER SHALL REVIEW THESE DETAILS PRIOR TO CONSTRUCTION TO VERIFY SUITABILITY. © PRINSCO, INC.



1717 16TH ST. NE WILLMAR, MN 56201 www.prinsco.com

| | HDPE PIPE - STRUCTURE CONNECTION - A-LOK WITH PIPE SLEEVE | | | | | |
|--|---|--------|--------|-----------|-----------------|--|
| | | | | | | |
| | DRAWN B | Y: NJW | DATE: | 24-Jul-23 | DRAWING NUMBER: | |
| | SCALE: | NTS | SHEET: | 1 OF 1 | D-1-116 | |