

PVC INLET PIPE
STAINLESS STEEL BAND RUBBER SLEEVE POLYPROPYLENE MAINLINE PIPE A FULL CONNECTION DETAIL 161 SCALE NTS

	EZ TEE REFERENCE TABLE								
	INLET PIPE	HOLE SAW	MAINLINE DIAMETER	INLET PIPE	HOLE SAW	MAINLINE DIAMETER			
	4"	4.50"	8" - 18"	10"	10.875"	15" - 18"			
			24" - 60"			24" - 60"			
	6"	6.50"	10" - 18"	12"	12.875"	18"			
			24" - 60"			24" - 60"			
	8"	8.75"	12" - 18"	15"	15.813"	24" - 60"			
			24" - 60"						

NOTES:

- EZ-TEES ARE AVAILABLE IN 4", 6", 8", 10", 12" AND 15" SIZES.
- INCLUDES RUBBER SLEEVE, PVC ADAPTER, STAINLESS STEEL BAND, AND PRE-INSTALLED GASKET.
- PVC ADAPTER SHALL MEET REQUIREMENTS OF ASTM D1784 AND ASTM F794.
- RUBBER SLEEVE AND GASKET SHALL MEET REQUIREMENTS OF ASTM F477.
- FOR MORE INFORMATION CONTACT YOUR LOCAL PRINSCO REPRESENTATIVE.

PRINSCO WATER MANAGEMENT SOLUTIONS

1717 16TH ST. NE WILLMAR, MN 56201 www.prinsco.com

TITLE: HP PIPE - TAPPED CONNECTION -							
EZ TEE FOR PVC							
DRAWN BY:	TRA	DATE:	11-Jun-25	DRAWING NUMBER:			
SCALE:	NTS	SHEET:	1 OF 1	D-2-161			

THIS DETAIL DEPICTS RECOMMENDED INSTALLATION PRACTICES AND IS NOT INTENDED TO SUPERSEDE ANY NATIONAL, STATE OR LOCAL SPECIFICATIONS. PRINSCO BEARS NO RESPONSIBILITY FOR ANY ALTERATIONS, REVISION AND/OR DEVIATION FROM THIS STANDARD DETAIL. PRINSCO HAS NOT PERFORMED ANY ENGINEERING OR DESIGN SERVICE FOR THIS PROJECT. THE DESIGN ENGINEER SHALL REVIEW THESE DETAILS PRIOR TO CONSTRUCTION TO VERIFY SUITABILITY, © PRINSCO, INC.